

CITY OF BALTIMORE WET WEATHER CONSENT DECREE SMOKE AND  
DYED WATER TESTING FORM

Page 1 of 3

Sewershed: Dundalk

Consultant: RJN Group, Inc.

Date: YYYYMMDD

2008 10 8 121

Test to be performed:  
Smoke ☒ Dye ☐

Ground Condition:  
☒ Dry ☐ Damp ☐ Wet

Supervisor initials: TS

Manhole ID: S71W-007MH

Test ID: 1047- 106

Notifications - made daily: ☒  
(Residents, Fire, 311)

Field Sketch: Show all manholes with numbers, blower placement location, sandbag or isolation device location, street names, building addresses and locations, defect locations and photograph numbers.

Dundalk Ave

Brentwood Ave

Sand Bags

S71W-009MH

Holabird Ave

6701

X DB02

Downspouts / p.c. lat

196'

1801

X DB01

p.c. / o

S71W-007MH

Sand bags

SMOKE BLOWER

**rjn**group

CITY OF BALTIMORE WET WEATHER CONSENT DECREE SMOKE AND DYED WATER TESTING FORM		Page <u>1</u> of <u>3</u>
Sewershed: Dundalk	Consultant: RJN Group, Inc.	Date: YYYYMMDD <u>2008 10 8 121</u>
Test to be performed: Smoke <input checked="" type="checkbox"/> Dye <input type="checkbox"/>	Ground Condition: <u>Dry</u> Damp Wet	Supervisor initials: <u>TS</u>
Manhole ID: <u>S71W-007MH</u>	Test ID: 1047- <u>106</u>	Notifications - made daily: <input checked="" type="checkbox"/> (Residents, Fire, 311)



S1047-106-OB01-P01 Private Cleanout, medium smoke, pavement.



S1047-106-OB02-P01 Private Lateral, medium smoke, pavement.